



December 2, 2013

MEMORANDUM

TO: Aaron Glick, City Planner I
Planning and Development Department

FROM: Lisa King
Traffic Technician Senior

**Subject: Krispy Kreme Merrill Road PUD
R-2013-0720
CDN 7185.002**

Upon review of the referenced application, and based on the information provided to date, the Development Services Division has the following comments.

1. Plans were submitted for 10 set review under City Development Number 7185.002 on 11/4/13. Exhibit F(1) Site Plan in application packet closely resembles what was submitted for review in 10 set. Traffic has no comments on proposed Site Plan.
2. Signs, fences, wall & landscaping shall not obstruct horizontal line of sight at intersection per FDOT Design Standards Index 546.

Please understand that this does not constitute approval of the design elements. Approval of the design elements (driveway location, dimensions, roadway geometry, traffic circulation, etc.) shall be facilitated through the 10-set and 10-set review process. If you have any questions regarding the comment outlined above, please call me directly at 255-8586.